

STATE OF CALIFORNIA
STATE AND CONSUMER SERVICES AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: cbssc@dgs.ca.gov

Office Use Item No. _____

PARTICIPATION COMMENTS FOR THE NOTICES DATED MAY 13, 2011
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: JUNE 27, 2011

From: _____ Date: June 18, 2011

Dan Kaiser (Signature)
Name (Print or type)

Access Services Plus
Agency, jurisdiction, chapter, company, association, individual, etc.

1548 Columbia St Redlands CA 92374-2265
Street City State Zip

I/We (do)(do not) agree with:

[**Do Not**] The CDPH Agency proposed modifications As Submitted on Section No. **3111B, and 3114B**
and **Figure 31B-7**

and request that this section or reference provision be recommended:

[] Approved [] Disapproved [] Held for Further Study [**X**] Approved as Amended

Suggested Revisions to the Text of the Regulations:

It appears to have been no coordination with this chapter and the State's or Federal disabled access requirements. Suggest the Commission modify for consistency.

(1) 3111B.3

(a) This section uses a term "safety railings" when the balance of the code refers to the same device as "handrails".

(b) Two handrails should be provided for consistency with other sections of the CBC and ADA 1009.6.2 ; and spaced between 20" and 24" apart

(2) 3114B.1 (and wherever it may occur) – Change "handicap" to a more appropriate term, i.e. disabled access assistance device

(3) Figure 31B-7 –

(a) Handrail extension at the top must extend a minimum 12" horizontally

(b) The bottom of the handrail should be shown to extend to the nosing of the bottom tread

Criteria Nos: 1, 6,

Reason: [The reason should be concise if the request is for "Disapproval," "Further Study," or "Approve As Amend" and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]